


Mono IP67 CE

INSTRUCTION



- 1.The installation must be done by competent electricians.
- 2.Product can not be modified.
- 3.Make sure the power has been switched off before installation.
- 4.The product is a class III luminaire and shall be connected with a constant current driver according to the specifications in the above sheet.
- 5.When connecting more than one fixture, these are connecting in series, from plus to minus.
- 6.The connection of the luminaire, should be stranded with 0.5mm -1.5mm conductor.²
- 7.The specification for the driver means determines on the voltage and the maximum number of luminaires per loop.
- 8.Power should never be regulated on the secondary side.
- 9.See the installations on the image below.

